



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 5/8/09

Code 62.4.6.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY- ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2005
Section number and title E3902.9		Page 494
Proponent David Kish	Title	
Address 210 Floyd Ct., West Lafayette, IN 47906		Phone (765) 491-4902
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
(a) change the title of Section E3902.9 to read: "wet locations."		
(b) At the end of Section E3902.9 add a new sentence to read as follows: All 15- and 20-ampere, 125- and 250-volt nonlocking receptacles shall be listed weather resistant type.		
REASON		
This provision insures receptacles are appropriate for the expected ambient conditions.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		